

NOTICE OF SERVICE INTERRUPTION/WORK FORM

Date of Request (yyyy/mm/dd): _____		Requester: _____	
Start Date – End			
Start Date (yyyy/mm/dd) _____	Time (s) _____	Notes _____	
End Date (yyyy/mm/dd) _____	Time (s) _____	_____	
Building(s) Affected:		1: _____	2: _____
		3: _____	4: _____
Areas/Rooms Affected: _____			
Service to be interrupted:		1: _____	2: _____
		3: _____	4: _____
Description/Reason for Project:			
Contractor: _____		Phone #: _____	
Contractor/Project Managers: _____		Phone #: _____	
Should you have any questions or concerns, please contact			
Notes:			

University of Windsor

Panel Schedule

Job No. **06212**

Panel: **LP-1D4A**

Date: 1-Mar-07

Voltage: **120 / 208**

Panel Mains: 225 amps

Mounting: SURFACE

Ph/Wire: **3/4**

Tub Type: Single

Location: M1100

Fed from: **DP-2A1**

Main Breaker: None

Remarks: Provide double neutral

BRKR	*	DESCRIPTION	C [W]	d.f.	D [W]	cct	bus	cct	D [W]	d.f.	C [W]	DESCRIPTION	*	BRKR
20A-1P		C1100 Lighting	972	1	972	1	a	2	548	1	548	W1100,1 Lighting		20A-1P
20A-1P		C1100 Lighting	1036	1	1036	3	b	4	810	1	810	1115 Lighting		20A-1P
20A-1P		1100A-E,J C1106 Lighting	1200	1	1200	5	c	6	918	1	918	1115 Lighting		20A-1P
20A-1P		1100F-H Lighting	1032	1	1032	7	a	8	972	1	972	1115 Lighting		20A-1P
20A-1P		C1105,8 Lighting	936	1	936	9	b	10	810	1	810	1113 Lighting		20A-1P
20A-1P		C1104-5 Lighting	1134	1	1134	11	c	12	918	1	918	1113 Lighting		20A-1P
20A-1P		1102,4 Lighting	1008	1	1008	13	a	14	464	1	464	1116 Lighting		20A-1P
20A-1P		1106,8 Lighting	944	1	944	15	b	16	644	1	644	1113B Lighting		20A-1P
20A-1P		1110,2,4 Lighting	944	1	944	17	c	18	972	1	972	1113 Lighting		20A-1P
20A-1P		1109,11 Lighting	1180	1	1180	19	a	20	1250	1	1250	C1100-2 Lighting		20A-1P
20A-1P		C1105,J1110,1101,W1102 Lighti	778	1	778	21	b	22	1200	1	1200	C1101 Lighting		20A-1P
20A-1P		1105,7 Lighting	944	1	944	23	c	24	1200	1	1200	C1101 Lighting		20A-1P
20A-1P		Stair No. 3 lighting	216	1	216	25	a	26	1020	1	1020	C1101 Lighting		20A-1P
20A-1P		OUTDOOR Lighting	192	1	192	27	b	28	1152	1	1152	C1100 Lighting		20A-1P
20A-1P		C1101 Lighting	400	1	400	29	c	30	630	1	630	C1101 Lighting		20A-1P
20A-1P		C1102,V1101,1118 Lighting	743	1	743	31	a	32	0	1		Spare		20A-1P
20A-1P		Spare		1	0	33	b	34	0	1		Spare		20A-1P
20A-1P		Spare		1	0	35	c	36	0	1		Spare		20A-1P
20A-1P		Spare		1	0	37	a	38	0	1		Space		
		Space		1	0	39	b	40	0	1		Space		
		Space		1	0	41	c	42	0	1		Space		

CONNECTED 'A' CONNECTED 'B' CONNECTED 'C' 9405 W
8502 W
9260 W

9405 W DEMAND 'A' DEMAND 'B' DEMAND 'C'
8502 W
9260 W

Notes:

TOTAL DEMAND AMPS	75.4	A
TOTAL CONNECTED LOAD	27.2	kW
TOTAL DEMAND LOAD	27.2	kW